

The concept of usage HRTSIM as a device for setting and certification of AVR

Alisher Askarov^{1,*}, and *Nikolay Ruban*¹

¹National Research Tomsk Polytechnic University, 634050 Tomsk, Russia

Abstract. This paper presents the analysis of application Hybrid Real-Time Power System Simulator (HRTSim), developed at National Research Tomsk Polytechnic University, as a device for setting and certification of automatic voltage regulators (AVR) for synchronous generators. The simulation results demonstrate that the proposed hardware-software complex (HSC) can be used for presented aim.

1 Introduction

The reliability level of the United Power System (UPS) of Russia is determined, among other factors, by reliability and operational characteristics of power facilities, devices and control systems, including the characteristics of the modern microprocessor devices of automated control, regulation, protection and automation.

However, the devices used in practice may have algorithmic or programming errors. Also they are not always adapted to the operating conditions in a real power system. That all leads to increase in the number of technological disturbances in power systems and decrease the reliability of parallel operation of power plants and power systems, as a whole. In particular, disconnection of a generating unit became more frequent due to the loss of excitation (incorrect operation of AVR) in power plants, moreover, due to the fact that interconnecting mains are usually “weak” and heavily loaded, it in turn causes the low-frequency (0,1-0,5 Hz) fluctuations with large amplitude in power systems and leads to a non-effective operation of AVR and false operation of protective relays [1-3].

Therefore, microprocessor devices of AVR used in new or modernized power facilities must be tested in conditions close to the conditions of future operation to ensure system reliability of the UPS of Russia [4], which, moreover, is obligatory, according to the standards of JSC “SO UPS” [5]. In accordance with [5], testing of the AVR settings is carried out – either on a physical model of the power system, either on a mathematical model of the power system using a hardware-software complex of real-time power systems simulation.

But at this moment, the certification of AVR is exclusively performed on the physical model of electric power system.

* Corresponding author: askalibah@gmail.com




Fig. 2. The model of the power system for AVR testing, realized in HRTSim, according to [5].

As a check of the correct operation of the AVR of synchronous generators has been performed test disturbances, according to the standard “SO UPS” [5]. In this paper presented the results of the next test disturbance – a step changing of voltage on the busbars of power station, where installed testing AVR, by connecting a capacitance $CI = 188$ MVAR to the busbars of this station (the busbars 500 kV PP No.1). Example of the correct operation of AVR at the entrance to the area of minimum excitation limit (MEL) and exit from the area of MEL, according to [5], is shown in Fig. 3a.




Fig. 3. Oscillograms of the AVR operation in case of MEL.

In this experiment has been verified the correctness of the AVR operation in the regime of minimum excitation limit. As can be seen from the oscillograms (Fig. 3b), when the balance of reactive power changed under connecting of capacitance, the voltage on the busbars of power plants increased and the excitation current reduced to the minimum value, what ensures the functioning of MEL, which does not allow violation of the static stability of the power system.

4 Analysis of the obtained results

In this article for the first time proposes to use HRTSim for setting and certification of AVR, which combines the advantages of physical and mathematical simulation of power systems.

Further work lies in the development of the communication interface between HRTSim and real AVR devices and also in the modernization of the mobile version of the complex for onsite setting and certification, which in turn would reduce the time and cost of work. This development especially effective for:

- hydropower plants, where the hydro-generators and characteristics of power plant are purely individual;
- nuclear power plants, where full-scale and correct setting of AVR is required for security reasons.

Also the relevance of this work is confirmed by many Russian companies such as JSC “Rosenergoatom Concern”, PJSC “RusHydro”, PJSC “INTER RAO” [13].

This work was supported by the Ministry of Education and Science of the Russian Federation under the governmental grant “Science” No. 13.5852.2017/BCH (Development of the concept for comprehensive validation of calculating modes and processes in electric power system and tools of its realization).

References

1. A. Suvorov, Y. Borovikov, A. Gusev, A. Sulaymanov, M. Andreev, N. Ruban, R. Ufa, *Electr. Eng. J.* **99**, 959 (2017), DOI: 10.1007/s00202-016-0464-4
2. N. S. Kumar, J. Gokulakrishnan, *Int J. electr. power energy syst.* **33**, 1172 (2011)
3. A. Ghorbani, B. Mozafari, S. Soleymani, A.M. Ranjbar, *Turk. J. Elec. Eng. Comp. Sci.* **24**, 2575 (2016)
4. A. Gusev, A. Suvorov, A. Sulaymanov, *MATEC Web Conf.* **37**, 01023 (2015), DOI: 10.1051/mateconf/20153701023
5. STO 59012820.29.160.20.001-2012. Requirements to excitation systems and automatic voltage regulators of synchronous generators
6. A. A. Suvorov, A. S. Gusev, A. O. Sulaymanov, O. V. Suslova, *MATEC Web Conf.* **91**, 01052 (2017), DOI: 10.1051/mateconf/20179101052
7. A. S. Gusev, A. A. Suvorov, A. O. Sulaymanov, *IOP Conf. S.* **93**, 012016 (2015), DOI: 10.1088/1757-899X/93/1/012016
8. Y. Borovikov, A. Prokhorov, M. Andreev, *Proc. 7th Int. Forum Strategic Technol.* 341 (2012), DOI: 10.1109/IFOST.2012.6357822
9. A. Prokhorov, Y. Borovikov, M. Andreev, *Proc. 7th Int. Forum Strategic Technol.* 512 (2012), DOI: 10.1109/IFOST.2012.6357823
10. Y. S. Borovikov, A. Y. Pischulin, R. A. Ufa, *IOP Conf. S.* **93**, 012018 (2015), DOI: 10.1088/1757-899X/93/1/012018
11. H. Zimmer, B. Niersbach, J. Hanson, *Proc. 11th IEEE Int. Conf. CPE-POWERENG*, 71 (2017)
12. U. K. Verma, S. Banerjee, A. P. Singh. *Proc. 3rd Int. Conf. AEEICB*, 299 (2017)
13. M. Andreev, A. Sulaymanov, A. Suvorov, *MATEC Web Conf.* **37**, 01001 (2015), DOI: 10.1051/mateconf/20153701001